



MATERIAL APPROVAL SUBMITTAL

VIDA DUBAI MALL ON PLOT 132-133 - DOWNTOWN DEVELOPMENT

Employer: EMAAR DEVELOPMENT PJSC Project Manager: MORGANTI PROJECT MANAGEMENT SERVICES [MGI]
 Supervision Consultant: WSP MIDDLE EAST LTD [WSP] Supervision Architect: AEDAS/ WSP SUB CONSULTANT
 Cost Manager: RIDER LEVETT BUCKNALL [RLB] Main Contractor: SHAPOORJI PALLONJI MIDEAST. [SPML]

Discipline: Civil C Struct S Mech M Elec E Arch A Plmb P Submittal Ref: SPML-VDM-PLU-MAS-0043 REV. 00
 Location: Ground Floor to Podium-6, Tower 1, Tower 2 Date: 17th May 2020

List of Submitted Items:

Item	Description	No of Copies	Remarks
1.	Material & Sample Submittal for Bottle Trap for Wash Basins and Janitor Sinks	1 Soft Copy	Sample Board Attached

Manufacturer: M/s. Bonomini, Italy
 Supplier: M/s. Aquaplex L.L.C
 Ref. Spec (s): Sanitaryware Supply Matrix Ref. Drwg (s): VBD-WSP-SW-ZZ-DR-PHE-00030

Compliance Statement:

The Contractor hereby confirms that the submitted items have been reviewed in detail and are correct and in strict conformance with the Contract Documents. (compliance statement attached)

Initiator: [Signature] QA/QC Manager



Name, Signature & Date

REVIEWER'S COMMENTS

WSP (Str/MEP)

Please refer attached sheet for comments.

ARCHITECTS

No additional comments

ANISH THAHA [Signature]

20.05.2020



Name, Signature and date
Comments Sheet Attached? Yes No

Name, Signature and date
Comments Sheet Attached? Yes No

SUPERVISION CONSULTANT A B C D

Name & Signature: [Signature] Date: 20-05-2020

Note: The Engineer's / Consultants approval shall not in any way relieve the Contractor of his obligation under the Contract. The Contractor shall be solely responsible for the soundness and the correctness of the submitted Materials and Documents as per the required Contract Conditions and Contract Clauses

Codes: A: No Objection B: No Objection subject to comments C: Rejected, Revise & Resubmit D: For Information



SUBMITTAL REVIEW COMMENTS


VIDA DUBAI MALL ON PLOT 132-133 - DOWNTOWN DEVELOPMENT

Employer:	EMAAR DEVELOPMENT PJSC	Project Manager:	MORGANTI PROJECT MANAGEMENT SERVICES [MGI]
Supervision Consultant:	WSP MIDDLE EAST LTD [WSP]	Supervision Architect:	AEDAS/ WSP SUB CONSULTANT
Cost Manager:	RIDER LEVETT BUCKNALL [RLB]	Main Contractor:	SHAPOORJI PALLONJI MIDEAST. [SPML]

Submittal Ref	SPML-VDM-PLU-MAS-0043	Rev	0	Date of Review:	20.05.2020
Description:	Material & Sample Submittal for Bottle Trap for Wash Basins and Janitor Sinks.			Review Status:	A <input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/>

Serial	Item/Part /Area	Comment/Instruction/Observation	Reviewer /Remark
1	Technical	<ol style="list-style-type: none"> 1. No Objection for the proposed manufacturer" Bonomini / Italy", however below comments shall be complied for review prior to order placement. 2. Scope of matrix Sanitaryware's were noted. 3. Contractor to ensure that pipe length is suitable as per site requirements without any gap. 4. Ensure the accessibility of Bottle Trap future maintenance. 5. Proper / Approved sealant shall be applied during installation. 6. Depth of the trap shall meet the project specification requirements. 7. Final approval will be subject to mock up installation approval. 8. Colour and visibility of the trap subject to requirements of architect 	AT

Name: Anish Thaha

Signature: 

Date: 20-05-2020

Note: The Supervision Consultant's approval shall not in any way relieve the Contractor of his obligation under the Contract. The Contractor shall be solely responsible for the soundness and the correctness of the submitted Method Statements, Materials, Shop Drawings, Calculations and other Documents as per the Contract.

