



APPROVAL OF MATERIALS

Project: G + 4 TYPICAL FLOOR RESIDENTIAL BUILDING		REF No: AIC/J-736/AM/2015/19	
Plot No: RA-16	Location: JEBEL ALI	City: DUBAI	
Main contractor: A.I.C Contracting LLC			
Department	<input type="checkbox"/> Architectural	<input type="checkbox"/> Structural	<input type="checkbox"/> Plumbing <input type="checkbox"/> Electrical <input type="checkbox"/> Mechanical <input type="checkbox"/> Firefighting
Material	SS FLOOR GRATINGS		
S N	Specified Material	Same as Specified	Document Title
	SS FLOOR GRATINGS		Profile and Technical Data Sheet - 3 Sets
Subcontractor/Supplier AQUATEKNIK (FZE)			
Manufacturer / Local Agent ASAHI			
Enclosure Pre-qualification and Technical Data Sheet			
Reason For Alteration			
Submitted by: Eng. Mahmoud Heiba	Signature:	Date: 7/07/2015	
Received By Alabdooli Eng. Azzam	Signature:	Date: / /	
Below portion for ALABDOOLI use only			
Status :	<input type="checkbox"/> Approved	<input checked="" type="checkbox"/> Approved as noted	<input type="checkbox"/> Rejected <input type="checkbox"/> Re submitted
Comments:	SS-316		
	Guarantee 10 years.		
Signed by	Signature:	Date: 26/7/2015	
Handed over to	Signature :	Date :	

*Alabdooli will require two weeks from submission date for clearing the above documents.

Site # 574



SUPPLIER/MATERIAL APPROVAL FORM

PROJECT : B+G+7 Storey Residential Building on Plot No. 231-169 at Al Nahda First, Dubai

CLIENT : M/s Dubai Investments Real Estate Co. LLC.

CONTRACTOR : M/s Al Arif Contracting Company

NAME OF SUPPLIER : AQUATEKNIK PLUMBING MERCHANTS TRADING LLC

NAME OF MATERIAL : ASAHI SS FLOOR GRATING

SPEC/BOQ/DWG. REF. (Enclose Copy) :

SAMPLE SUBMITTED : YES / NO YES / NO LITERATURE SUBMITTED : YES / NO

FORM SUBMITTED BY MAIN CONTRACTOR : Rashed Name [Signature] Signature 14/12/014 Date

Answer

FORM RECEIVED BY QHC : Name Signature Date

QHC COMMENTS : Approved 4-1-15 Approved with comments:

Submittal is incomplete. The following is required:

Rejected, because

QHC REPRESENTATIVE APPROVAL : [Signature] DATE: 5/1/15

CLIENT'S APPROVAL : DATE:

QHC HEAD OFFICE APPROVAL : [Signature] DATE: 5/1/15

FORM RECEIVED BY MAIN CONTRACTOR : Name Signature Date

Copy for Raju



Construction of 2B+G+6 Floor + Gym Roof Building on Plot No. 373-0401, Al Barsha First, Dubai for Mr. Abdel Latif Bel Ghouzooz, Mr. Yahah Bel Ghouzooz & Mr. Ibrahim Bel Ghouzooz



Material Approval Submittal

MAS Ref. No. MS/MEPP/GS#284/11 Date: 30-03-16
Rev. No. 0 Sample tag Ref. No. _____

Discipline: Architectural Structural Mechanical Electrical Plumbing Fire Protection Others

Material Details

Item Description: FLOOR TRAP COVER, FLOOR CLEAN OUT COVER & BALCONY DRAIN COVER BOQ Item No.: _____

Name of Material: ASAHI (SS-304 WITH 20 YEARS WARRANTY) Reference Spec. Clause: _____

Location of intended use: AS PER DRAWING Drawing Ref.: _____

Manufacturer / Local Supplier: AQUATEKNIK P.O BOX. 9630, SHARJAH Country of Origin: _____

Reason for Submittal: For Approval For Information Others ()

Remarks: As per Original Alternative

Attachments: Drawing Spec. Sample Catalog Others ()

For Contractor			Receipt Acknowledged by High Art
Prepared by Material Engineer: <u>Mr. Seejl Jamal...</u>	Signature: _____	Date: <u>30-03-16.....</u>	Received By: _____
Checked by QA Manager: _____	Signature: _____	Date: _____	Date: _____
Approved by Engg. Manager: _____	Signature: _____	Date: _____	Time: _____
Project Manager Contractor: <u>Mr. Kolanji Nadhan</u>	Signature: _____	Date: <u>30-03-16.....</u>	




Engineer's Review & Comments:

No objection

Returned to Contractor with Status:

A: Approved B: Approved as noted C: Revise / Resubmit D: Information

For Engineer	Receipt Acknowledged by Contractor
Signature: _____	Received by: _____
Date: _____	Date: <u>20 APR 2016</u>



Distribution: Employer Project Manager Cost Management Arch. Sub Consultant other ()

MATERIALS SAMPLE SUBMITTAL FOR APPROVAL

Ref. No. MS/MEP/PL/015

PROJECT : G+4P+19 Typical +Gym+Roof-Residential Building
AREA & PLOT NO. : 134-0908
EMPLOYER : Mr. Mohammad Aqil Ali Alzarooni
ENGINEER : Inspiration Engineering Consultants
CONTRACTOR : Beijing Emirates International Construction Co.
MEP CONTRACTOR : EMT Electromechanical Works LLC

1. **MATERIAL TYPE :** MEP Architectural Structural
MATERIAL DISCRPTION : FLOOR DRAIN FLOOR CLEAN OUT COVER AND BALCONY DRAIN (SAMPLE)
SUBMITTAL STATUS : NEW SUBMITTAL RE-SUBMITTAL NO.
TYPE OF DOCUMENTS:- Data Sheet Catalogue Certificate Sample Test Results

Area of Application : All Building
 Drawing Ref. :
 Specification Ref. :

B.O.Q. Ref. No. :
 Standards :

Attached all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. **MANUFACTURER/SUPPLIER :**
 Company Name : ASAHI
 Local Agent : AQUATEKNIK (FZE)
 Address : DUBAI, UAE

3. **DELIVERY :**
 Country of Origin : PRC
 Availability
 Locally Manufactured Overseas

Delivery : Ex-works/ Total Duration
 Estimated Time of Arrival on Site
 Program : Date Material Required on Site
 Latest Date for Order

Beijing Emirates International
 Construction Co. LLC
 (Site No: 903 - Al Mamzar)
 (Plot No: 134-0908)
 (Construction Site)

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by : *Wasim* Signature: *Wasim* Date: 27/11/17

Submitted by : Signature: *Mohammed* Date: 27/11/17

RECEIVED
 27 NOV 2017
Mohammed

Received by: Signature: Date:
 4. **ENGINEER'S COMMENTS:**
 Approved
 Approved As Noted
 Resubmit For Approval
 Rejected

x Full delivery to be Complied with approved Material Submittal.
Follow approved shop drawings.
subject to approved mockup floor.

27/11/17

Returned by: Signature: *Mohammed* Date: 29/11/17

Received by: Signature: Date:
 It remains that engineer's discretion to instruct certain testing to be carried out by independent laboratory at the contractor's cost.

MATERIALS SUBMITTAL FOR APPROVAL

Ref. No. MS/MEP/PL/009

PROJECT : G+4P+19 Typical +Gym+Roof-Residential Building
 AREA & PLOT NO. : 134-0908
 EMPLOYER : Mr. Mohammad Aqil Ali Alzarooni
 ENGINEER : Inspiration Engineering Consultants
 CONTRACTOR : Beijing Emirates International Construction Co.
 MEP CONTRACTOR : EMT Electromechanical Works LLC

1. MATERIAL TYPE : MEP Architectural Structural
 MATERIAL DISCIPTION : SS FLOOR DRAIN, FLOOR CLEAN OUT COVER AND BALCONY DRAIN (1ORIGINAL + 2 COPIES)
 SUBMITTAL STATUS : NEW SUBMITTAL RE SUBMITTAL NO.
 TYPE OF DOCUMENTS:- Data Sheet Catalogue Certificate Sample Test Results

Area of Application : All Building
 Drawing Ref. : B.O.Q. Ref. No. :
 Specification Ref. : Standards :
 Attached all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate

2. MANUFACTURER/SUPPLIER :
 Company Name : ASAH
 Local Agent : AQUATEKNIK (FZE)
 Address : DUBAI, UAE

3. DELIVERY :
 Country of Origin : PRC
 Availability
 Locally Manufactured Overseas

Delivery : Ex-works/ Total Duration
 Estimated Time of Arrival on Site
 Program : Date Material Required on Site
 Latest Date for Order

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated, also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely

Submitted by : *WASIM* Signature: *heip* Date: *29/01/2017*

Submitted by : Signature: *[Signature]* Date: *30/01/2017*

Received by: Signature: *sk* Date: *30/1/17*

4. ENGINEER'S COMMENTS:
 Approved
 Approved As Noted
 Resubmit For Approval
 Rejected

* S.S floor drain, cleanout, balcony drain & shower drain from ASAH is approved. (304 AISI).
 * size & qty. to be as per approved drawings.
 * Sample to be submitted for client approval

Returned by: Signature: *[Signature]* Date: *01/02/2017*

Received by: Signature: *[Signature]* Date: *1/2/2017*

It remains that engineer's discretion to instruct separate tests to be carried out by independent laboratory at the contractor's cost

RECEIVED
27 NOV 2017

BY: *[Signature]*
Ref. MS.MEP.PL.015

EMT received